

City of Bandon

555 Hwy 101, PO Box 67 Bandon, OR 97411 (541) 347-2437

Bandon by the Sea

CITY COUNCIL CONSENT AGENDA	DATE: 01-09-2023
SUBJECT: CONSOLIDATED MUNICIPAL UTILITY REPORT	ITEM NO: 3.8

BACKGROUND:

The accompanying Consolidated Municipal Utility Report is for November/December 2023 and provides reports from the three public utilities (enterprises).

FISCAL IMPACT:

Report Only

RECOMMENDATION:

Motion to approve as part of the Consent Calendar Items.

SUBMITTED BY:

DENISE RUSSELL, UTILITIES OFFICE MANAGER

ELECTRIC DEPT MONTHLY REPORT December 29, 2023

The Electric Department is responsible for the safe distribution of power to the citizens of Bandon and the surrounding area. The duties include, as the budget and time permits:

- Maintaining overhead and underground power lines, substations, and metering systems.
- Building new lines, connecting new services, and undergrounding overhead lines within the city limits.

THIS MONTH'S WORK:

New Services

- The crew connected four new electrical service in December.
- There are 70 active bid packets on file. These projects have either paid
 planning fees or have an active building permit from the State. Future
 homes are waiting for the State Building Department to approve their
 building plans so they can start to build. A bid packet includes the cost
 for service setup, a map for conduit installation, digging instructions,
 and examples of the specifications required. Inquiries into the cost of
 power from prospective buyers of bare lots have slowed as have plans
 from planning.

Upcoming Projects and Updates

- The engineers are working on an Electric System Model that will lead to a System Coordination Study and a Cost-of-Service Study. The Cost-of-Service Study is a third-party study that will help the City determine where electric rates should be set. All these reports are overdue.
- The City is required by the PUC to test its power poles on a ten-year rotation to ensure they are uncompromised by rot or a number of other things. The inspected area included 300 poles from Beach Loop and Highway 101, North to 12th Street and Highway 101, of which ten need replacement. The crew has started to replace these power poles.
- The Electric Department is getting a new meter reading system because the old hardware is no longer supported by the vendor.
- We are also in the process of getting a new updated mapping system to use in our coordination study.

CONSOLIDATED MUNICIPAL UTILLITY 12-4-2023 PAGE 3 OF 9

Outages.

We had two unplanned outages in December.

Topics for discussion

The Electric Department is moving forward with the implementation of the new mapping software through Gartrell. The new mapping system will better track pole inspections, inventory, new construction, and maintenance issues, and get the information to the engineers to complete a coordination study. Operationally, this is a big step in improving and tracking everything.

The Electric Department has hired a new employee for the position of utility worker.

Submitted By:

JIM WICKSTROM, ELECTRIC SUPERVISOR

CONSERVATION DEPARTMENT MONTHLY REPORT

November 2023

The City contracts with the Efficiency Services Group (ESG) to administer an energy savings program funded by Bonneville Power Administration (BPA). The City Conservation Department oversees and provides direction to ESG; and ESG processes all commercial, industrial, and residential rebates, performs all audits and inspections, and reports energy savings to BPA.

City staff assist customers by providing forms and answering questions. ESG provides a toll-free telephone number for technical questions and support. Once ESG staff assist customers with completing appropriate applications and paperwork, completes the audit(s) and/or inspection(s), paperwork is transferred to City staff to process and distribute rebates to customers.

In November, four energy efficiency rebates were distributed for furnaces. The total amount distributed in rebates was \$2,560.00.

Submitted by:

DENISE RUSSELL, UTILITIES OFFICE MANAGER

CITY COUNCIL CONSENT AGENDA	DATE: 12-7-2023
SUBJECT: WATER TREATMENT PLANT	ITEM NO:

BACKGROUND:

Attached are the monthly reports for November 2023. This month we had the power convertor for our chlorine generator go out. (Miox Machine)

We have also started weekend minimal operations training with Public Works employee, Danile Senn.

FISCAL IMPACT:

Replacement of power convertor for the Miox Machine was roughly \$4,100.00.

RECOMMENDATION:

With recent events of having a lack of employee coverage at the Water Plant, we have started cross training Public Works employee, Daniel Senn, into basic daily operations routine.

Motion to approve as part of the Consent Calendar Items.

SUBMITTED BY:

JIM YOURAVISH, WATER PLANT OPERATOR

City of Bandon Water Utility

Annual Water Usage Report

Month	Gallons of Water Leaving Plant	Gallons of Water Backwashed	Gallons of Water Sold	Percent Loss
Dec-22	15,180,833	756,170	13,375,721	-7.27
Jan-23	14,047,257	527,986	11,136,251	-17.63
Feb-23	14,451,243	528,410	11,210,944	-19.48
Mar-23	11,634,654	754,901	9,461,461	-13.04
Apr-23	12,171,224	603,528	9,057,661	-21.70
May-23	12,588,393	602,963	9,223,932	-23.04
Jun-23	15,888,642	960,071	13,117,550	-12.13
Jul-23	18,910,932	1,118,357	14,305,910	-19.60
Aug-23	22,961,432	894,880	17,242,592	-21.86
Sep-23	23,198,342	745,256	20,604,903	-8.23
Oct-23	19,213,977	746,612	14,377,709	-22.15
Nov-23	16,592,727	596,949	11,983,074	-25.09
Total	198,839,656	8,836,083	155,097,708	-17.50

Gallons of Water Discharged represents treated unmetered water that has been discharged by the City during the course of performing routine utility maintenance.

Per State water guidelines, water utilities should not exceed 15% water loss over the course of one year.

WATER TREATMENT	PLANT A	MENT PLANT ACTIVITY REPORT
NOVE	NOVEMBER 2023	23
PARAMETERS	WATER PLANT OPERATIONS	EPA ALLOWABLE LIMIT
WATER TREATED (GALLONS)	13,207530	
DAILY AVERAGE (GALLONS)	440,251	
TREATED WATER LEAVING PLANT	15,197,291	
AVERAGE TURBIDITY(NTUS)	.032	MAXIMUM 30
AVERAGE PH (7.00 IS NEUTRAL)	7.65	MINIMUM 7.1 LEAVING PLANT
AVERAGE CHLORINE RESIDUAL LEAING PLANT (PPM)	0.55	TRACE AT LAST CONNECTION MAXIMUM 4.0
WEEKLY FECAL COLIFORM AND E. COLI TEST	0 POSITIVE	0 POSITIVE FOR FECAL COLIFORM & E. COLI TAKEN IN DISTRIBUTION SYSTEM
THE WATER TREATEMENT PLANT MET ALL EPA REQUIREMENTS FOR THE MONTH OF NOVEMBER 2023.	A REQUIREMENTS F	OR THE MONTH OF NOVEMBER 2023.

CITY COUNCIL CONSENT AGENDA	DATE: 12-4-2023
SUBJECT: WASTEWATER TREATMENT PLANT	ITEM NO:

BACKGROUND:

Attached is the monthly Wastewater Plant activity report for November 2023.

The City's Wastewater facility treated 8,111,000 gallons of wastewater this month, for an average of 270,000 gallons treated daily. All permit requirements were met for the month of November 2023.

FISCAL IMPACT:

None

RECOMMENDATION:

Motion to approve as part of the Consent Calendar Items.

SUBMITTED BY:

STEVEN JAMES, TREATMENT PLANT OPERATOR

WASTEWATER PLA	ANT ACTIVITY R	EPORT FOR NO	VEMBER 2023		
EFF Effluent - outgoing	solids PPM Parts permillion (same s MG/L) g untreated wastewater MG/L Milligrams per liter ng treated wastewater MLS Milliliters of water gen demand (strength of wastewater)				
Table 1: Treatment Plant Operations					
PARAMETERS AND UNITS	MAXIMUM SUMMER DEQ PERMIT	MAXIMUM WINTER DEQ PERMIT	AVERAGE MONTHLY OPERATIONS		
EFF BOD AVERAGE					
MG/L or PPM	20	30	8		
POUNDS/DAY	75	110	16		
EFF TSS AVERAGE					
MG/L or PPM	20	30	7		
POUNDS/DAY	75	110	15		
FECAL COLIFORM					
COLONIES/100 MLS	14	14	9		
INF FLOW AVERAGE					
GALLONS/DAY			270,000		
INF SOLIDS AVERAGE		DESIGN	RECEIVED		
BOD POUNDS/DAY		1150	844		
TSS POUNDS/DAY		1350	834		

^{1.} TREATMENT PLANT OPERATIONAL SYNOPSES

The Wastewater Plant has met all DEQ permits for the month of November 2023.

*SUMMER MAY 1 -OCTOBER 31 **WINTER NOVEMBER 1 -APRIL 30